

The Department of Ecology does NOT warranty the Data and/or the Information on this Well Report.

31-4E-13G



WATER WELL REPORT

Original & 1st copy - Ecology, 2nd copy - owner, 3rd copy - driller

Construction/Decommission ("x" in circle) 198434

Construction
 Decommission ORIGINAL INSTALLATION Notice of Intent Number _____

CURRENT

Notice of Intent No. W 207615

Unique Ecology Well ID Tag No. AHP-019

Water Right Permit No. _____

Property Owner Name LAKEWOOD CREST LLC

Well Street Address 199XX SILL RD

City ARLINGTON County SNOHOMISH

Location SW/4-1/4 NE/4 Sec 13 Twn 31 R 4 EWM or WWM circle one

Lat/Long (s, t, r) Lat Deg _____ Lat Min/Sec _____

Still **REQUIRED** Long Deg _____ Long Min/Sec _____

Tax Parcel No. 310413-001-005-CO 201#3

PROPOSED USE: Domestic Industrial Municipal
 DeWater Irrigation Test Well Other _____

TYPE OF WORK: Owner's number of well (if more than one) _____
 New well Reconditioned Method: Dug Bored Driven
 Deepened Cable Rotary Jetted

DIMENSIONS: Diameter of well 6 inches, drilled 88 ft.
 Depth of completed well 87 1/2 ft.

CONSTRUCTION DETAILS
 Casing Welded 6" Diam. from 0 ft. to 82 1/2 ft.
 Installed: Liner installed _____" Diam. from _____ ft. to _____ ft.
 Threaded _____" Diam. from _____ ft. to _____ ft.

Perforations: Yes No
 Type of perforator used _____
 SIZE of perfs _____ in. by _____ in. and no. of perfs from _____ ft. to _____ ft.

Screens: Yes No K-Pac Location 82
 Manufacturer's Name JOHNSON
 Type STAINLESS Model No. _____
 Diam. 6" Slot size 0.016 from 82 1/2 ft. to 87 1/2 ft.
 Diam. _____ Slot size _____ from _____ ft. to _____ ft.

Gravel/Filter packed: Yes No Size of gravel/sand _____ ft.
 Materials placed from _____ ft. to _____ ft.

Surface Seal: Yes No To what depth? 19 ft.
 Material used in seal BENTONITE
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

PUMP: Manufacturer's Name _____
 Type: _____ H.P. _____

WATER LEVELS: Land-surface elevation above mean sea level _____ ft.
 Static level 73 ft. below top of well Date 4-10-06
 Artesian pressure _____ lbs. per square inch Date _____
 Artesian water is controlled by _____ (cap, valve, etc.)

WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? _____
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

 Date of test _____
 Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Airtest 15+ gal./min. with stem set at 85 ft. for 1 hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? Yes No

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure, and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information. (USE ADDITIONAL SHEETS IF NECESSARY.)

MATERIAL	FROM	TO
TOPSOIL	0	2
TAN CLAY & SAND	2	6
TAN SAND GRAVEL	6	15
CLAY		
GRAY CLAY & GRAVEL	15	35
GRAY SAND & GRAVEL	35	62
PEA GRAVEL	62	88
WATER		

RECEIVED

JUN 13 2006

DEPT. OF ECOLOGY

Start Date 4-4-06 Completed Date 4-4-06

WELL CONSTRUCTION CERTIFICATION: I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

Driller Engineer Trainee Name (Print) DALE WESTBY
 Driller/Engineer/Trainee Signature [Signature]
 Driller or trainee License No. 2711

Drilling Company ARLINGTON WELL DRILLING
 Address 29121 SR 9 NE
 City, State, Zip ARLINGTON WA 98223

If TRAINEE,
 Driller's Licensed No. _____
 Driller's Signature _____

Contractor's
 Registration No. ARLINWD969JLW Date 4-6-06

Ecology is an Equal Opportunity Employer.